

NORTHWEST LABORATORIES

of Seattle, Incorporated

ESTABLISHED 1896

Technical Services for: Industry, Commerce, Legal Profession & Insurance Industry

FAX: (206) 622-0159

1530 FIRST AVENUE SOUTH
SEATTLE, WASHINGTON 98134

Telephone: (206) 622-0680

Report To: Alaskan Copper

Date: October 13, 1992

Report On: Asbestos Analysis/Bulk Samples

Lab No.: E 61276

SUBMITTED:

One (1) Bulk Samples/Asbestos Analysis

IDENTIFICATION:

Sample #1 Table Top M26279

ANALYSIS BY POLARIZED LIGHT/DISPERSION STAINING MICROSCOPY:


<u>Sample</u> <u>No.</u>	<u>Asbestos, %</u>	<u>Other Fibrous</u> <u>Materials</u>	<u>Non-Fibrous</u> <u>Materials</u>	<u>Comments</u>
1	Chrysotile, 30 *Total Asbestos: 30%	-----	Cement Sand	**

*Note 1: This Sample Contains Asbestos. Greater than 1% Asbestos is Asbestos Containing Material.

Note 2: Common Asbestos Forms; Chrysotile, Most Common Form, Amosite, Second Most Common Form.

**Note: Cement - asbestos; friable if broken

NORTHWEST LABORATORIES


Sam LeBaron, Director
Analytical Laboratory

kf

AKC-0013846

INVOICE

REMITTANCE COPY

NORTHWEST LABORATORIES

of Seattle, Incorporated

1530 FIRST AVENUE SOUTH • SEATTLE, WASHINGTON 98134 • (206) 622-0680
FAX: (206) 622-0159

- Alaskan Copper & Brass
628 Hanford
Seattle, Washington 98134
Attention: Gerald Thompson

Date October 13, 1992

Report No. E 61276

Order No. P.O. #M26279

IRS No. (b) (6)

TERMS: Net, 30 days. No statement will be sent unless requested.

Past due balances are subject to a service charge of 1½% per month, or if less, the maximum amount permitted by applicable law.

Asbestos Analysis/Bulk Sample

One (1) Bulk Sample at \$35.00 ea

\$35.00

Sample #1 Table Top M26279

Reference:

001-50-20
kf/el

9

SAMPLES DISCARDED WITHIN TWO MONTHS UNLESS OTHERWISE REQUESTED IN WRITING BY YOU.

AKC-0013847